

AN ORDER OF THE CLEAN ENVIRONMENT COMMISSION  
UNDER THE CLEAN ENVIRONMENT ACT

RE: The Clean Environment Commission and the Village of Manitou, applicant

WHEREAS Pursuant to the provisions of The Clean Environment Act, the Village of Manitou submitted an application to The Clean Environment Commission to prescribe limits in connection with the operation of a sewage lagoon system located on part of the SE 1/4 of Section 31-3-8 WPM and with effluent discharge to Mary Jane Creek,

AND WHEREAS No representation was made to The Clean Environment Commission by any person who is, or is likely to be, affected by an Order of the Commission prescribing limits in connection with the said operation,

AND WHEREAS The Clean Environment Commission considered the application on the 24th day of June, 1974, on the 8th day of July, 1974, and again on the 8th day of October, 1974,

IT IS HEREBY ORDERED THAT

1. The applicant shall, within six months of the date of issuance of this Order, file with The Clean Environment Commission a proposal whereby the said sewage lagoon system is expanded and enlarged to meet the other requirements of this Order,
2. The applicant shall, within two years of the date of issuance of this Order, complete the expansion and enlargement of the said sewage lagoon system to provide adequate treatment of the sewage and sufficient storage capacity for winter holding of effluent so as to meet the requirements of this Order,
3. The applicant shall ensure that within two years of the date of issuance of this Order the following requirements are met:
  - (a) that all facilities for the treatment of sewage and holding of effluent are maintained and operated in such a manner as to prevent the contamination of groundwater,

*Assigned to Water Protection Section - EGK  
CBO/BY  
Dec 28/74*


3. cont'd . . . .

- (b) that the said sewage lagoon system is operated in such a manner as to minimize the release of offensive odours,
- (c) that loading on the primary cell does not exceed 50 pounds per acre per day,
- (d) that the characteristics of the effluent of the said sewage lagoon system to the Mary Jane Creek are such that:
  - (i) the biochemical oxygen demand (5-day BOD) does not exceed 30 milligrams per litre, and
  - (ii) the total coliform content as reflected by the MPN index does not exceed 1500 per 100 millilitres of sample,
- (e) that no discharge of effluent from the said sewage lagoon system takes place in the period between the 1st day of November of any year and the 15th day of May in the following year.

Order No. 395

Dated at the City of Winnipeg

this 21ST day of OCTOBER, 1974.

  
Chairman  
Clean Environment Commission