

AN ORDER OF THE CLEAN ENVIRONMENT COMMISSION
UNDER THE CLEAN ENVIRONMENT ACT

RE: THE CLEAN ENVIRONMENT COMMISSION and SASAGIU RAPIDS LODGE LTD., Applicant

WHEREAS pursuant to the provisions of The Clean Environment Act, Sasagiu Rapids Lodge Ltd., filed a proposal with the Department of Mines, Resources and Environmental Management for the operation of a sewage treatment system located in Township 71, Range 7, WPM in the Local Government District of Mystery Lake, on the East side of Provincial Highway 391, approximately 50 miles South of Thompson, Manitoba, with discharge of effluent to the Grass River,

AND WHEREAS in the absence of limits being prescribed by a Regulation under the said Act, the proposal was referred to The Clean Environment Commission for the prescribing of limits,

AND WHEREAS no representation was made to the said Commission by any person who is, or who is likely to be affected by an Order of the Commission prescribing limits in connection with the said operation,

AND WHEREAS the said Commission considered the application on the 21st day of January, 1975,

IT IS HEREBY ORDERED THAT

1. The Applicant shall ensure that the said sewage treatment system is constructed, maintained and operated in such manner as to:
 - (a) Prevent the contamination of groundwater; and
 - (b) Minimize the release of offensive odours;
2. The Applicant shall ensure that the organic loading (in terms of five-day biochemical oxygen demand) on the said sewage treatment system does not exceed seven pounds per day;
3. The Applicant shall ensure that the quality of the effluent from the said sewage treatment system is such that:


*Assigned to Water
Calcutin Section
Jan 21/75
CSO/BS*

- (a) the biochemical oxygen demand (5-day BOD) does not exceed 30 milligrams per litre; and
 - (b) the nonfilterable residue (suspended solids) do not exceed 30 milligrams per litre;
4. The Applicant shall ensure that the effluent from the said sewage treatment system is continuously chlorinated so as to produce a residual, after 15 minutes contact, of not less than 0.5 milligrams of chlorine per litre, before the effluent is released into the Grass River.

Order No. 424

Dated at the City of Winnipeg

this 24th day of January , 1975


Chairman
The Clean Environment Commission