

AN ORDER OF THE CLEAN ENVIRONMENT COMMISSION
UNDER THE CLEAN ENVIRONMENT ACT

RE: THE CLEAN ENVIRONMENT COMMISSION and THE MANITOBA WATER SERVICES BOARD,
Applicant,

WHEREAS pursuant to the provisions of The Clean Environment Act, the Manitoba Water Services Board, filed a proposal with the Department of Mines, Resources and Environmental Management for the operation of a sewage lagoon system located in the South 1/2 of Section 1-11-3 WPM in the Rural Municipality of Cartier, Manitoba, to serve the unincorporated village of Blie, with discharge of effluent to a highway ditch and thence to an unnamed creek and thence to the Riviere Sale;

AND WHEREAS in the absence of limits being prescribed by a Regulation under the said Act, the proposal was referred to The Clean Environment Commission for the prescribing of limits;

AND WHEREAS no representation was made to the said Commission by any person who is, or is likely to be, affected by an Order of the Commission prescribing limits in connection with the said operation;

AND WHEREAS the said Commission considered the said proposal on the 28th day of April, 1975;

IT IS HEREBY ORDERED THAT

1. The Applicant shall ensure that the said sewage lagoon system is constructed, maintained and operated in such a manner as to:

*Assigned to Water
Collection District
May 20/75
GMB/MS*

Cancelled

1. Cont'd . . .

- (a) prevent the contamination of groundwater;
- (b) minimize the release of offensive odours; and
- (c) ensure the organic loading, in terms of five-day biochemical oxygen demand, on the primary cell of the said sewage lagoon system does not exceed 50 pounds per acre per day.

2. The Applicant shall ensure that no discharge of effluent from the said sewage lagoon system takes place between the first day of November in any year and the fifteenth day of May of the following year.


3. The Applicant shall ensure that the quality of the effluent from the said sewage lagoon system, before discharge is such that:

- (a) the biochemical oxygen demand (B.O.D.) does not exceed 30 milligrams per litre; and
- (b) the total coliform content, as indicated by the MPN index, does not exceed 1,500 per 100 millilitres of sample.

Order No. 454

Dated at the City of Winnipeg

this 15 day of MAY, 1975.



Chairman,
Clean Environment Commission