

"Binder Copy"

AN ORDER OF THE CLEAN ENVIRONMENT COMMISSION  
UNDER THE CLEAN ENVIRONMENT ACT

RE: THE CLEAN ENVIRONMENT COMMISSION and F. CURE, ESQ., Applicant,

WHEREAS pursuant to the provisions of The Clean Environment Act, F. Curé, Esq., filed a proposal with the Department of Consumer and Corporate Affairs and Environment in connection with the operation of a sewage lagoon system located on Lot 50, Township 18, Range 10, EPM (Title No. E46503) in the Local Government District of Alexander, Manitoba, and serving the Curé Trailer Park with discharge of effluent via a drainage ditch to the Winnipeg River;

AND WHEREAS in the absence of limits, terms, and conditions prescribed by a regulation under the said Act, the application was referred to The Clean Environment Commission for the prescribing of limits, terms, and conditions;

AND WHEREAS after giving notice, the Commission received a representation from a person who is likely to be affected by an order of the Commission issued in connection with the said operation;

AND WHEREAS the Commission held a hearing in Pine Falls on the 26th day of January, 1981;

AND WHEREAS the Commission considered the proposal on the 16th day of February, 1981;

IT IS HEREBY ORDERED THAT

1. The Applicant shall construct, maintain and operate the said sewage lagoon system in such a manner that:
  - (a) the release of offensive odours is minimized;
  - (b) the contamination of groundwater is prevented; and
  - (c) the organic loading on the primary cell, in terms of five-day biochemical oxygen demand, is not in excess of 56 kilograms per hectare per day.

Assigned  
To WATER  
Pollution Control  
March 2/81  
J.

2. The Applicant shall not permit the discharge of effluent from the said sewage lagoon system where the organic content of the effluent is, as indicated by five-day biochemical oxygen demand, in excess of 30 milligrams per litre.
3. The Applicant shall not permit the discharge of effluent from the said sewage lagoon system where the fecal coliform content of the said effluent is, as indicated by the MPN index, in excess of 200 per 100 millilitres of sample.
4. The Applicant shall not permit the discharge of effluent from the said sewage lagoon system between the 1st day of November of any year and the 15th day of May of the following year.

Order No. 910

Dated at the City of Winnipeg  
this 26th day of February, 1981.

  
\_\_\_\_\_  
Chairman,  
The Clean Environment Commission.

File: 2403.0