



73
C-6-207

300-419 GRAHAM AVE. WINNIPEG 1
TELEPHONE 946-7785

March 2nd, 1971.

ORDINARY LICENCE - MANITOBA HYDRO,
GREAT FALLS GENERATING STATION,
Section 27-17-11E, Local Government District of Alexander

This licence is issued pursuant to The Clean Environment Act permitting Manitoba Hydro to discharge contaminants or wastes arising from the operation of septic tank systems serving the Great Falls Generating Station and the machine and power house located on Section 27-17-11E, Local Government District of Alexander, into the Winnipeg River, subject to the following conditions:

- (1) The licensee shall ensure that the septic tanks are constructed in such a manner as to prevent the contamination of groundwater.
- (2) The licensee shall ensure that the contaminants or wastes treated in the said septic tanks are chlorinated to a chlorine residual of 0.5 milligrams per litre after 15 minutes contact before release of effluent takes place to the Winnipeg River.

Chairman,
The Clean Environment Commission.

*Assigned to Engg. Department
16 Feb 72
W.M.W.*

*cc: Reg. Services
Aug 28/73*