



March 14, 2016

Project No: 141-21811-00

Mr. Asit Dey, P.Eng.

Environmental Engineer

MANITOBA CONSERVATION AND WATER STEWARDSHIP

160-123 Main Street

Winnipeg, MB R3C 1A5

Dear Mr. Dey:

**RE: R.M. OF MACDONALD - COMMUNITY OF SANFORD
WASTEWATER STABILIZATION POND EXPANSION
ENVIRONMENT ACT PROPOSAL – FILE No: 1921.10**

This letter intends to address and clarify a paragraph in the EAP regarding the hauling of outside septage and wastewater to the Sanford Lagoon. The 4th, 5th and 6th lines in the 2nd paragraph of Section 3.1, Pg. 5, reads:

“This lagoon does not receive truck-hauled septage or wastewater. The Oak Bluff Lagoon is the designated municipal lagoon to receive outside truck-hauled wastewater and septage.”

This should read as follows:

“This lagoon does not receive **outside** truck-hauled septage or wastewater. The Oak Bluff Lagoon is the designated municipal lagoon to receive outside truck-hauled wastewater and septage.”

The existing Sanford Lagoon receives truck-hauled wastewater from only the Community of Sanford. The Lagoon receives the liquid portion of the wastewater from the Community’s low-pressure sewer system via a lift station and forcemain. The solids portion of the wastewater collects in septic tanks, which are emptied and hauled to the Lagoon once a year during the summer months.

Best regards,

WSP Canada Inc.



Dana Bredin, P.Eng.
Geotechnical / Civil Engineer

cc: Mr. Daryl Hrehirchuk – CAO, R.M. of Macdonald
Mr. Grant Baker – Public Works, R.M. of Macdonald