

## Dey, Asit (SD)

---

**From:** Dey, Asit (SD)  
**Sent:** September-11-18 1:20 PM  
**To:** 'Bunn, Jason'; Darren Hofer (se\_hofer@hotmail.com)  
**Cc:** Burland Ross, Siobhan (SD); Winsor, Jennifer (SD); Kneeshaw, Tyler (CON) (Tyler.Kneeshaw@gov.mb.ca); Rackham, Jay (CWS) (Jay.Rackham@gov.mb.ca)  
**Subject:** 2018-09-11\_liner.aproval.letter\_riverdale.colony\_file1981.20

Hello Jason and Darren,

Good afternoon. Receipt of the soil liner test results submitted by Mr. Jason Bunn, P.Eng., of WSP Canada Inc. on September 6, 2018 for the recently constructed new primary and secondary cells of Riverdale Colony's (Licencee) wastewater treatment lagoon (lagoon) is acknowledged.

The test results indicate that the soil liner of the new primary and secondary cells meets the requirements of Clause 16(c) of Environment Act Licence No. 2868 R (Licence) regarding hydraulic conductivity.

Authorization to operate the new primary and secondary cells of the wastewater treatment lagoon, and in accordance with the limits, terms, and conditions of the Licence is hereby provided pursuant to Clause 19 of the Licence.

Per Clause 15 of the Licence, the Licencee is required to submit the record drawings by January 11, 2019.

Per Clause 38 of the Licence, the Licencee shall, during the first year of operation of the Development following construction of the wastewater treatment lagoon that a discharge must occur, obtain and analyze grab samples of the effluent during each effluent discharge campaign and report the results of the analysis in accordance with Schedule "B" of the Licence.

Per Clause 41 of the Licence, The Licencee shall decommission the wastewater treatment lagoon that was operating under Licence No. 963 and the supplementary unlicensed secondary cell in accordance with Clauses 39 and 40 of this Licence within one year of commencing operation of the Development.

If you have any questions regarding these matters, please contact me at (204) 945-2614 or at [asit.dey@gov.mb.ca](mailto:asit.dey@gov.mb.ca).

Thanks,

Regards,

Asit Dey, P.Eng., Environmental Engineer  
Department of Sustainable Development  
Environmental Approvals Branch  
Government of Manitoba  
1007 Century Street  
Winnipeg, MB R3H 0W4  
T: (204) 945-2614 F: (204) 945-5229  
Email: [asit.dey@gov.mb.ca](mailto:asit.dey@gov.mb.ca)