



**DATE:** Aug 6, 2013

## Memorandum

**TO:** Rafiqul Chowdry  
Environmental Approvals Branch  
160-123 Main Street, Winnipeg,  
MB  
R3C 1A5

**FROM:** Joy Kennedy  
Water Quality Management Section  
Water Science and Management Branch  
160-123 Main Street, Winnipeg, MB  
R3C 1A5

**Cc** David Hay

**TELEPHONE:** 945-7908

**FACSIMILE:** 948-2357

**EMAIL:** joy.kennedy@gov.mb.ca

**SUBJECT: ENVIRONMENT ACT PROPOSAL FILE: 3888.10 RM OF WOODLANDS  
WASTEWATER TREATMENT LAGOON UPGRADE**

- The RM of Woodlands must define a monitoring and evaluation plan to demonstrate the effectiveness of the trickle discharge nutrient reduction strategy for phosphorous. A year-end report confirming concentration and total removal rates along the length of the municipal ditch and third order drain should be submitted by the RM of Woodlands to the Director.
- The Water Quality Management Section is concerned with any discharges that have the potential to impact the aquatic environment and/or restrict present and future uses of the water. Therefore it is recommended that the license require the proponent to actively participate in any future watershed based management study, plan/or nutrient reduction program, approved by the Director.

Joy Kennedy