



Conservation and Water Stewardship

Environmental Stewardship Division
Environmental Approvals Branch
123 Main Street, Suite 160, Winnipeg Manitoba R3C 1A5
T 204 945-8321 F 204-945-5229
www.gov.mb.ca/conservation/eal

Client File No. 2506.10

January 8, 2016

Tannis Lodge
Chief Administrative Officer
R.M. of Lac Du Bonnet
Box 100
Lac Du Bonnet, MB ROE 1A0
Email: rmldb@lacdubonnet.com

Dear Ms. Lodge:

Re: Rural Municipality of Lac du Bonnet wastewater treatment lagoon - wastewater effluent limit for phosphorus in effect January 1, 2016

As you have been previously notified, your wastewater treatment lagoon is required to meet the 1 mg/L phosphorus limit as of January 1, 2016 in accordance with the Water Quality Standards, Objectives and Guidelines Regulation under *The Water Protection Act*.

The current expansion of your wastewater treatment lagoon for the Rural Municipality of Lac du Bonnet operates under Environment Act Licence 1773 R. Upon the complete construction and commissioning of the facility, Licence 1773 will be rescinded and Clause 19 of Licence 1773 R will apply. In the interim, in addition to meeting the 1 mg/L phosphorus limit and in accordance with Clause 2 of Licence 1773 R, you are required to sample, analyze and report on the total phosphorus content of your wastewater effluent prior to discharging to surface water.

Should you have questions, please call Rob Boswick at 204-945-6030.

Yours sincerely,

“original signed by”
Tracey Braun, M.Sc.
Director

c: Don Labossiere/Donna Smiley, Environmental Compliance and Enforcement Branch
Nicole Armstrong, Director, Water Science and Management Branch
Rob Boswick, Environmental Approvals Branch
Public Registries