

Webb, Bruce (CWS)

From: Webb, Bruce (CWS)
Sent: September-30-13 2:57 PM
To: Steele, Tania (CWS)
Subject: Cartier Regional Water Cooperative Water Treatment Plant Expansion File: 4351.10

The attached material can be placed in the public registries for the above project:

Additional information request: No additional information required.

Public Comments on Proposal: No public comments received.

Technical Advisory Committee Comments on Proposal: (10 pages)

Manitoba Conservation and Water Stewardship - Environmental Programs and Strategies Branch, Air Quality Management Section, September 5, 2013

Manitoba Conservation and Water Stewardship – Watersheds and Protected Areas Branch, September 24, 2013

Manitoba Conservation and Water Stewardship – Lands Branch, September 24, 2013

Manitoba Conservation and Water Stewardship – Parks and Natural Areas Branch, August 27, 2013

Manitoba Conservation and Water Stewardship – Office of Drinking Water, August 28, 2013

Manitoba Conservation and Water Stewardship – Water Use Licensing Section, August 7, 2013

Manitoba Conservation and Water Stewardship – Water Control Works and Drainage Licensing Section, September 4, 2013

Manitoba Infrastructure and Transportation – Highway Planning and Design Branch, Environmental Services Section, September 3, 2013

Manitoba Local Government – Community and Regional Planning Branch, September 6, 2013

Manitoba Health – Medical Officer of Health, Southern Health, August 20, 2013

Office of the Fire Commissioner, August 26, 2013

Bruce.

Comments Cartier Water Treatment Plant Expansion

BW

The followings are the comments on the proposal:

- As mentioned in the proposal, it is expected that construction best practices and appropriate control measures will be utilized during construction to minimize dust generation and vehicle/equipment emissions.
- It is also expected that appropriate scheduling of site activities will be followed to mitigate the noise and vibration effects.

Webb, Bruce (CWS)

From: Kaita, Adara (CWS) on behalf of +WPG1212 - Conservation_Circulars (CWS)
Sent: September-24-13 9:23 AM *BW*
To: Webb, Bruce (CWS)
Subject: EA Proposal - Cartier Regional Water Coop - Water Treatment - File: 4351.10

Hi Bruce,

Sorry for the late response. The Watersheds and Protected Areas Branch have no concerns.

The Lands Branch notes that the proponent should be advised that the adjacent section of the Assiniboine River has been identified for future designation as the Assiniboine River Clam Beds Proposed Ecological Reserve. All assurances that sedimentation management is incorporated into any construction activity as many of the ditches in the area lead to the river.

Thank you,

Adara Kaita
Crown Land Programs and Policy Manager
Conservation and Water Stewardship
Box 25, 200 Saulteaux Crescent
Winnipeg, MB R3J 3W3
Cell: (204) 945-6301
F: (204) 948-2197

Webb, Bruce (CWS)

From: Kelly, Jason (CWS)
Sent: August-27-13 8:28 AM
To: Webb, Bruce (CWS) BW
Subject: Request for comments due September 9 , 2013 - R.M. of Cartier Water Treatment- File: 4351.10

Parks and Natural Areas Branch has reviewed the proposal filed pursuant to the Environment Act for the Request for comments due September 9 , 2013 - R.M. of Cartier Water Treatment- File: 4351.10. The Branch has no comments to offer as this does not impact any parks or ecological reserves.

Jason Kelly, M.N.R.M.
Ecological Reserves and Protected Areas Specialist
Parks and Natural Areas Branch
Conservation and Water Stewardship
Box 53, 200 Saulteaux Cres
Winnipeg, MB R3J 3W3

Phone: 204-945-4148
Cell:
Fax: 204-945-0012

Email: Jason.Kelly@gov.mb.ca

Webb, Bruce (CWS)

From: Stibbard, James (CWS)
Sent: August-28-13 10:40 AM *BW*
To: Webb, Bruce (CWS)
Subject: Re: 4351.10 Cartier Regional Water Coop New Headingley WTP and System Expansion EAP

Mr. Webb,

Office of Drinking Water reviewed the above noted EAP and noted no cause for concern respecting drinking water safety. However, this project will require a Permit to Construct or Alter a Public Water System, under Section 7 (1) of *The Drinking Water Safety Act*. Given the scope and complexity of the project, the review of the Permit Application and issue of the Permit will take some time. As such, we recommend the proponent submit the application package for the Permit to Construct as soon as it is finalized in order to obtain the Permit as expeditiously as possible.

If you have any questions, please call.

Regards,

James Stibbard P. Eng.
Approvals Engineer
Office of Drinking Water
1007 Century Street
Winnipeg MB R3H 0W4
phone: (204) 945-5949
fax: (204) 945-1365
email: James.Stibbard@gov.mb.ca
website: www.manitoba.ca/drinkingwater

Confidentiality Notice: This message, including any attachments, is confidential and may also be privileged and all rights to privilege are expressly claimed and not waived. Any use, dissemination, distribution, copying or disclosure of this message, or any attachments, in whole or in part, by anyone other than the intended recipient, is strictly prohibited.

Webb, Bruce (CWS)

Subject: FW: Request for comments due September 9 , 2013 - R.M. of Cartier Water Treatment- File: 4351.10

From: Matthews, Rob (CWS)
Sent: August-07-13 7:28 PM
To: Webb, Bruce (CWS) *BW*
Cc: McCombe, Christopher (CWS); Dey, Asit (CWS); Butterfield, Tamara (CWS); Lee, Mark (MWS)
Subject: RE: Request for comments due September 9 , 2013 - R.M. of Cartier Water Treatment- File: 4351.10

Bruce,

Here are my comments on this EAP:

The following paragraph appears on page 7 of the Environment Act Proposal for this project:

An application for a new Water Rights Act Licence for the RM of Headingley WTP will be required. Based on average day demand the current annual allocation of water to the CRWC would be sufficient to meet the needs of both the St. Eustache WTP (1070 dam³) and the Headingley WTP (2735 dam³).

The Water Use Licensing Section (WULS) is in agreement that a separate application will be required for this project as it represents a separate point of diversion on the Assiniboine River and a separate service area from the existing St. Eustache WTP.

We are also in agreement that the water use requirement for the new plant at Headingly should come out of the current allocation of the St. Eustache WTP as there is sufficient water set aside for both projects in the licence for the existing plant at St. Eustache.

Cheers,

Rob Matthews, Manager, WULS.

Webb, Bruce (CWS)

Subject: FW: Request for comments due September 9 , 2013 - R.M. of Cartier Water Treatment- File: 4351.10

From: Roberts, Dan (CWS)

Sent: September-04-13 1:36 PM

To: Webb, Bruce (CWS) *BW*

Subject: FW: Request for comments due September 9 , 2013 - R.M. of Cartier Water Treatment- File: 4351.10

On behalf of the *Water Control Works and Drainage Licensing Section*, there are no concerns.

Dan Roberts


Water Resource Officer

Water Control Works and Drainage Licensing Section

Conservation and Water Stewardship

Box 640, 201 Fourth Ave. S., Swan River, MB R0L 1Z0

Cell: (204) 281-2122, Fax: 734-3733



Infrastructure and Transportation
Highway Planning and Design Branch
Environmental Services Section
1420 - 215 Garry St., Winnipeg, MB R3C 3P3
T (204) 619-4359 F (204) 945-0593

September 3, 2013

Tracey Braun, M. Sc. *BW*
Director, Environmental Approvals Branch
Manitoba Conservation and Water Stewardship
123 Main St., Suite 160
Winnipeg, MB R3C 1A5

RE: Cartier Regional Water Cooperative Inc. – WTP Expansion
Client File No 4351.10

Dear Ms. Braun:

MIT has reviewed the proposal noted above and we do not have concerns with the development as proposed.

However, we would like to remind the proponent that detailed plans of water lines within, adjacent or crossing any provincial road right-of-way will have to be submitted to MIT for review and approval prior to installation.

For more information about this process, please contact Joelle Coulombe at Joelle.Coulombe@gv.mb.ca.

Thank you very much for providing us the opportunity to review the proposal.

Sincerely,

Ryan Coulter, M. Sc., P. Eng.
Manager of Environmental Services

Webb, Bruce (CWS)

Subject: FW: Request for comments due September 9 , 2013 - R.M. of Cartier Water Treatment- File: 4351.10

From: Gray, Richard (MLG)

Sent: September-06-13 5:38 PM

To: Shaler, Samantha (MLG); Webb, Bruce (CWS) *BW*

Subject: RE: Request for comments due September 9 , 2013 - R.M. of Cartier Water Treatment- File: 4351.10

Our office has no concerns with this proposal.

*Richard Gray, Planner
Manitoba Local Government
Community and Regional Planning
1-2210 Saskatchewan Ave. West
Portage la Prairie, MB R1N 0X1
Phone: 1 (204) 239-3347
Fax: 1 (204) 239-3459
e-mail: Richard.Gray@gov.mb.ca*

Webb, Bruce (CWS)

Subject: FW: Request for comments due September 9 , 2013 - R.M. of Cartier Water Treatment- File: 4351.10

From: Buchan, Shelley (HEALTH)

Sent: August-20-13 4:01 PM

To: Webb, Bruce (CWS)

Subject: FW: Request for comments due September 9 , 2013 - R.M. of Cartier Water Treatment- File: 4351.10

Hello Bruce

I don't have any health concerns with the proposal for the expansion of the Water Treatment Plant/System. Providing safe potable water in sufficient quantities promotes good health.

Thank you.

Shelley

DR SHELLEY BUCHAN

Medical Officer of Health /Medecin hygieniste

Southern Health-Santé Sud

180 Centenaire Drive

Southport, MB R0H 1N1

Tel: 204 428 2726 Fax: 204 428 2779

Email: Shelley.Buchan@gov.mb.ca

Web: www.southernhealth.ca

Together leading the way for a healthier tomorrow.

Ensemble vers un avenir plus sain.

Webb, Bruce (CWS)

Subject: FW: Request for comments due September 9 , 2013 - R.M. of Cartier Water Treatment- File: 4351.10

From: Kubish, Cheryl (OFC)

Sent: August-26-13 1:49 PM

To: Webb, Bruce (CWS) BW

Subject: FW: Request for comments due September 9 , 2013 - R.M. of Cartier Water Treatment- File: 4351.10

With respect to the water treatment plant expansion, the Office of the Fire Commissioner recommends that the licence requirement stipulates that the applicant obtain a building permit and occupancy permit from the Building Code authority, the RM of Headingley located at 126 Bridge Road, Headingley.

There should also be a Fire Safety Plan developed in consultation with the Headingley Fire Department as noted in Section 2.8 of the Manitoba Fire Code.

Cheryl Kubish
Administrative Assistant
Office of the Fire Commissioner
508-401 York Avenue
Winnipeg MB R3C 0P8
Phone: 945-3328
Fax: 948-2089

E-Mail address: Cheryl.Kubish@gov.mb.ca
