

Director  
Environmental Approvals Branch  
Manitoba Sustainable Development  
1007 Century Street  
Winnipeg, MB R3H 0W4

January 4, 2019

**Project #**  
60247924.402

To the Director:

**Subject: Notice of Alteration – Environmental Act Licence No. 2991**

On behalf of the City Brandon, please find enclosed a Notice of Alteration and design brief for the proposed Kirkcaldy lift station and forcemain as part of the City of Brandon's wastewater collection system falling under Environmental Act Licence No. 2991.

The new Kirkcaldy lift station and forcemain are expected to be in operation by fall 2019, with the lift station currently under construction and the forcemain contract is expected to be out for tender by the end of January 2019.

The new lift station and forcemain will replace the existing inverted siphon crossing, which was deemed a major basement flooding risk during the 2011 Assiniboine River flood. Upon completion of the lift station and forcemain project, the existing inverted siphon crossing, which includes two (2) combined sewer overflow locations at the Assiniboine River, will be abandoned.

The proposed alteration will not increase the volume of wastewater conveyed for treatment to the City of Brandon's municipal wastewater pre-treatment facility (MWWTF), centralized wastewater treatment facility (CWWTF) or wastewater treatment lagoon system.

We submit this Notice of Alteration as a minor alteration to the Environment Act Licence No. 2991 for your review.

Sincerely,  
**AECOM Canada Ltd.**



Mike Gaudreau, P.Eng.  
Municipal Engineer  
mike.gaudreau@aecom.com

MG:ag  
Encl.