



**Conservation and Water Stewardship**

Environmental Stewardship Division  
Environmental Approvals Branch  
123 Main Street, Suite 160, Winnipeg, Manitoba R3C 1A5  
T 204 945-8321 F 204 945-5229  
[www.gov.mb.ca/conservation/eal](http://www.gov.mb.ca/conservation/eal)

**File: 5721.00**

July 24, 2015

Ms. Marlene Biles  
Chief Administrative Officer  
Municipality of Oakland-Wawanesa  
Box 28  
Nesbitt MB R0K 1P0  
[oakwawa@outlook.com](mailto:oakwawa@outlook.com)

Dear Ms. Biles:

**Re: Municipality of Oakland-Wawanesa – Wawanesa Wastewater Treatment Lagoon  
Environment Act Licence No. 3117**

This is further to liner test results for the above facility provided by Delbert Friesen of Earth Max on July 23, 2015. The liner's hydraulic conductivity meets the requirements of Clause 17 of the above licence, and so approval to operate the facility is provided pursuant to Clause 20 of the Licence.

If you have any questions regarding this matter, please contact me at (204) 945-7021 or at [Bruce.Webb@gov.mb.ca](mailto:Bruce.Webb@gov.mb.ca).

Yours truly,

*“original signed by”*

Bruce Webb, P. Eng.  
Water Development and Control  
Assessment Officer  
Environmental Approvals Branch

c: Delbert Friesen, Earth Max  
Lin Watt, Dillon Consulting  
Dee Genaille, Manitoba Water Services Board  
Don Labossiere/Tim Prawdzik, Environmental Compliance and Enforcement Branch  
Peter Crocker/Kristy Forrestall, Environmental Compliance and Enforcement Branch  
Public Registries